



कार्यालय नगर परिषद तुमसर



(जिल्हा भंडारा महाराष्ट्र)

फोन नं ०७९८३ - ऑ. २३२३३६ मु. २३२९५७

email- co.mc.tumsar@gmail.com

NPT/F.V./ 196 /2024

Date :- 22/02/2024

FIRE SAFETY CERTIFICATE

This is Certified that Principal of Sunflag School, Bhandara situated at Bhandara Road, Warthi (Gram Panchayat Eklari), Dist. Bhandara has installed Fire Extinguishers AB (Foam Mechanical) Raining Capacity of 9 Liter with 3 Numbers and BC (Co2) 4.5 Kg Capacity of 13 Numbers for the protection of the safety in school premises.

1. School has instructed to get all the fire equipments inspected through Licensed agency in every six month i.e. January and July and get form B from Licensed agency. One copy of which has to be submitted mandatorily to the Municipal Council, Tumsar.
2. According to the Maharashtra Fire Prevention and Lifesaving Act 2006 it is mandatory to not install fire hydrant and sprinkar with alarm system.
3. Fire extinguisher equipments BC (Co2) of 4.5 Kg to 13 number & AB (Foam Machanical) of 9 Liters in 03 number were installed on 22/04/2024 and these are valid upto till 21/04/2029.
4. It is also cerified that Old Fire Extinguishers Equipments its Servicing, Refilling, Maintenance are in good conditions to run the school.



Sunflag

MANAGER
SUNFLAG SCHOOL
BHANDARA - 441905

[Signature]
Fire Officer,
Municipal Council, Tumsar
नगर परिषद तुमसर

PRINCIPAL
SUNFLAG SCHOOL
BHANDARA- 4419